



भारतीय खाद्य निगम , जिला कार्यालय, 973/2 एवं 3, सिंचाई कार्यशाला के सामने, ग्वालियर रोड सिविल लाइन,
झाँसी - 284001

दूरभाष- 0510-2332602, फ़ैक्स- 05102331433, ईमेल- jhansiup.fci@nic.in, वेब-साइट- fci.gov.in

Food Corporation of India, District office, 973/2 &3, Infront of Irrigation Workshop, Gwalior
Road, Civil Lines, Jhansi- 284001

Telephone- 0510-2332602, Fax- 05102331433 , E-mail – jhansiup.fci@nic.in Website – fci.gov.in

PRICE BID

Tender for S.I.T.C. of 25 K.V.A. output closed D.G. Set in acoustic enclosure on hire basis at Food Corporation of India District Office Jhansi

S. No.	Description of work
1	<p>Providing new weather proof three phase 25 K.V.A. noiseless (silent) DG set in sound attenuating acoustic enclosure with anti vibration mounting (AVM) pads (Dunlop make) with rated output of 415 volts 50 HZ consisting of Diesel Engine of Kirloskar /Cummins make for Air cooled coupledwith Alternator of Kirloskar / Standford/ Crompton make & enclosure of JAKSON / BHASKAR complete with accessories including base plate , fuel tank (capacity for minimum 8 hrs. of running) , batteries with leads and terminals , silencer , alarms standard engine control panel(manual) , utility piping , approved soundproof enclosure etc. complete in all respect as required. The D.G. Set & enclosure shall satisfy the norms of C.P.C.B.(Central Pollution Control Board) & A.R.A.I.(The Automotive Research Association of India)</p> <p>The quoted rate of D.G set on hire basis shall be inclusive of diesel, lubricant, operation and maintenance charges etc. for operation of DG set during working hrs. As specified in terms & condition enclosed.</p> <p>The DG set shall be equipped with following security & safety features :-</p> <ul style="list-style-type: none">● Glass control panel viewing window.● Externally accessible emergency stop button.● Provision for illumination inside enclosure.● High enclosure temperature safety.● Access to battery via lockable doors.● Externally accessible lockable fuel filling arrangement provided to the canopy● Special lockable door handles with single key.● Corrosion resistant modular construction (without any protruding parts)● Canopy is lined with acoustic foam which is non - igniting / fire retardant (conforming to BS 4735 / BIS – 7888)● Designed for installation in open air condition. <p>Operation of D.G. set during working hrs. including Sundays & holidays against power cut / single phasing/poor supply from supply company.</p>

1. Subject to the scope of work and terms & condition mentioned above/as per MTF I/We quote my/our over all rate/per month charges for one 25 K.V.A. output D.G. Set of Brand.....purchase year.....(invoice enclosed) as Rs...../(In words.....)

Our tender may kindly be accepted.

Place:.....

Date:.....

Signature of vendor with seal